



# BACNET OPTION USER GUIDE

## Chiller Control

Document number ECG-UG-18-011

This document is the property of Manufacturer and is delivered on the express condition that it is not to be disclosed, reproduced in whole or in part, or used for manufacture by anyone other than Manufacturer without its written consent, and that no right is granted to disclose or so use any information contained in said document.

Manufacturer reserves the right to change any product specifications without notice.

# IMPORTANT INFORMATION

## PURPOSE

This document aims to provide an overview on the BACNET option implemented on chiller controller.

Document Name	Document ID	Publication Date
BACNET User Guide	ECG-UG-18-011	January 2019

## REFERENCES

The following list includes all documents that may be the source of reference for material discussed in this publication.

- IOM Control
- IOM Machine
- Service Guide
- BACnet A Data Communication Protocol for Building Automation and Control Networks ANSI/ASHRAE Standard 135-2010

## CONVENTIONS

The following symbols are used to highlight important information in this document.



### CAUTION

This symbol is used to indicate potentially hazardous situations and conditions.



### IMPORTANT

This symbol is used to present information relevant to the topic.



### INFORMATION

This symbol is used to provide some useful information.

# REVISIONS HISTORY

REV	DATE	DESCRIPTION	DONE BY
Original	January 2019	<ul style="list-style-type: none"><li>Original document</li></ul>	MG/ER
A	October 2019	<ul style="list-style-type: none"><li>Remove unexpected text</li></ul>	ER

# ABBREVIATIONS

Abbreviation	Description
<b>AV</b>	Analog Value (BACnet object type)
<b>B-AAC</b>	BACnet Advanced Application Controller
<b>BAS</b>	Building Automation Systems
<b>BMS</b>	Building Management Systems
<b>BTL</b>	BACnet Test Laboratory
<b>BV</b>	Binary Value (BACnet object type)
<b>CAL</b>	Calendar (BACnet object type)
<b>CCN</b>	Proprietary Communication Protocol
<b>COV</b>	Change of Value
<b>DST</b>	Daylight Savings Time
<b>EL</b>	Event Log (BACnet object type)
<b>ID</b>	Identifier
<b>IR</b>	Intrinsic Reporting
<b>MV</b>	Multistate Value (BACnet object type)
<b>NC</b>	Notification Class (BACnet object type)
<b>PIC</b>	Product Integrated Controller
<b>PRG</b>	Program (BACnet object type)
<b>PV</b>	Present Value property
<b>RTC</b>	Real time clock
<b>RO</b>	Read-Only
<b>RW</b>	Read Write
<b>SCH</b>	Schedule (BACnet object type)
<b>TL</b>	Trend Log (BACnet object type)

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	5 OF 46

# CONTENTS

- 1 INTRODUCTION..... 7**
  - 1.1 SCOPE ..... 7
  - 1.2 BACNET ..... 7
- 2 HOW TO TRANSFORM A NON-BACNET CHILLER TO A BACNET CHILLER ..... 8**
  - 2.1 PREREQUISITES ..... 8
  - 2.2 SOFTWARE ACTIVATION KEY ..... 8
  - 2.3 LIST OF AVAILABLE SOFTWARE OPTIONS ..... 9
- 3 BACNET FOR CHILLER ..... 10**
  - 3.1 BACNET SETTINGS ..... 10
  - 3.2 BACNET PARAMETERS (BACNET) ..... 11
  - 3.3 DEVICE ID SETTING ..... 13
- 4 BACNET OBJECTS ..... 14**
  - 4.1 BACNET CHILLER OBJECTS ..... 14
  - 4.2 DEVICE OBJECT ..... 15
  - 4.3 ANALOG VALUE OBJECT ..... 16
  - 4.4 BINARY VALUE OBJECT ..... 17
  - 4.5 MULTISTATE VALUE OBJECT ..... 17
  - 4.6 NOTIFICATION CLASS OBJECT ..... 18
  - 4.7 EVENT LOG OBJECT ..... 19
  - 4.8 TREND LOG OBJECT ..... 19
  - 4.9 SCHEDULE OBJECT ..... 20
  - 4.10 CALENDAR OBJECT ..... 22
  - 4.11 FILE OBJECT ..... 22
  - 4.12 PROGRAM OBJECT ..... 22
  - 4.13 CHANGE OF VALUE (COV) ..... 23
  - 4.14 INTRINSIC REPORTING ..... 24
  - 4.15 COMMANDABLE ..... 25
  - 4.16 LOCK ..... 25
  - 4.17 READ WRITE ACCESS TO CHILLER ..... 26
- 5 I-VU, WEBCTRL COMPATIBILITY ..... 27**
  - 5.1 GENERAL OVERVIEW ..... 27
  - 5.2 COLOUR CHART ..... 27
  - 5.3 BACKUP & RESTORE CONFIG FILE ..... 28
- 6 IP ADDRESS SETTINGS ..... 29**
  - 6.1 IP ADDRESS CONTROLLER ..... 29
  - 6.2 IP ADDRESS MODIFICATION ..... 29
- 7 BACNET PICS ..... 30**
  - 7.1 PRODUCT DESCRIPTION ..... 30
  - 7.2 BACNET REQUIREMENTS BACNET STANDARDIZED DEVICE PROFILE (ANNEX L) ..... 30
  - 7.3 BACNET INTEROPERABILITY BUILDING BLOCKS (BIBBs)(ANNEX K) ..... 31
  - 7.4 STANDARD OBJECT TYPES SUPPORTED ..... 32
  - 7.5 DEVICE OBJECT TYPE ..... 33
  - 7.6 ANALOG VALUE (AV) OBJECT TYPE ..... 34
  - 7.7 BINARY VALUE (BV) OBJECT TYPE ..... 35
  - 7.8 MULTI-STATE VALUE (MSV) OBJECT TYPE ..... 36
  - 7.9 PROGRAM OBJECT TYPE ..... 36
  - 7.10 CALENDAR OBJECT TYPE ..... 37
  - 7.11 FILE OBJECT TYPE ..... 37
  - 7.12 SCHEDULE OBJECT TYPE ..... 38

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	6 OF 46

7.13	TREND LOG (TL) OBJECT TYPE.....	39
7.14	NOTIFICATION CLASS (NC) OBJECT TYPE.....	40
7.15	EVENT LOG (EL) OBJECT TYPE.....	40
7.16	DATA LINK LAYER OPTION .....	41
7.17	SEGMENTATION CAPABILITY.....	41
7.18	DEVICE ADDRESS BINDING .....	41
7.19	NETWORKING OPTIONS.....	41
7.20	NETWORK SECURITY OPTIONS.....	42
7.21	CHARACTER SETS SUPPORTED.....	42
7.22	SYSTEMVU SUPPORTED SERVICES .....	43
<b>8</b>	<b>BACNET IP COMMUNICATION TROUBLESHOOTING.....</b>	<b>44</b>
8.1	COMMUNICATION TROUBLESHOOTING.....	44
8.2	BACNET TOOL INCOMPATIBILITIES .....	45
8.3	BDT CANNOT DISCOVER BACNET DEVICE(S) .....	45
<b>9</b>	<b>BACNET OBJECT LIST .....</b>	<b>46</b>
9.1	OBJECT NAME/INSTANCE.....	46
9.2	BACNET OBJECT LIST DESCRIPTION .....	46

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	7 OF 46

# 1 INTRODUCTION

## 1.1 Scope

This guide describes the BACnet option for chillers. It is intended for Building Management System (BMS) engineers.

**The chiller controller supports the BACnet protocol over IP as B-AAC Equipment.**



**The BACnet stack is BTL certified.**

## 1.2 BACnet

**BACnet** is a *data communication protocol for building automation and control networks*. It is based on a client-server model and BACnet messages are referred to as "service requests".

The client machine ("user interface") sends the request to the server machine ("field device") that reports the result.

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	8 OF 46

## 2 HOW TO TRANSFORM A NON-BACNET CHILLER TO A BACNET CHILLER

### 2.1 Prerequisites


BACnet/IP (option 149) is an option which requires a Software Activation Key to be activated. This software-protected option can be factory-installed or installed on-site by the service technician or the customer.

### 2.2 Software activation key

The Software Activation Key is an individual license key based on machine MAC address.

#### To obtain the Software Activation Key

1. Please contact your local service representative.
2. Please beware that the controller **eth0/J15** MAC address will be requested in order to provide the correct Software Activation Key.
  - A **sticker** is present on the back of the panel (top right location) with J15 MAC. The address is coded using 12 digits: XX-XX-XX-XX-XX-XX
  - You may check the MAC address via the **user interface**.  
Go to the Configuration menu and select the *Add Options* menu (ADD\_OPT).  
The MAC address will be displayed.






ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	9 OF 46

## 2.3 List of available software options


The list of currently available software options can be verified via the user interface.


### To verify available software options

1. Go to the Main menu.
2. Select the *Software Options* menu (OPT\_STA).
  - The menu can be accessed when logged in (at least user-access level required).
3. If the status of the specific option is set to “Yes”, it means that the Software Activation Key for this option is installed.
4. Verify the status of the “OPT149: BACnet” parameter.
  - If the status of BACnet option is set to “No”, please go to section **Error! Reference source not found. Error! Reference source not found.** to see how to activate the software option.



OPT_STA - Software Options	
OPT5: Medium Brine	No
OPT6: Low Brine	No
OPT8: Light Brine	No
OPT149: BACnet	No
OPT295: Fast Cap Reco	No
OPT149B: Modbus	No

 The Software Options menu is read-only. Once the Software Activation Key is installed, the status of the option that was installed will change to “yes”.

 In case the controller is replaced, the Software Activation Key must be installed again.  
Please contact your local service representative for more information.

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	10 OF 46

## 3 BACNET FOR CHILLER

### 3.1 BACnet settings

The BACnet communication option can be enabled/disabled on the Chiller controller through the user interface.

To modify BACnet parameters:

- The user must be logged in at user-access level.
- Software Activation Key for BACnet must be installed.

#### To enable/disable BACnet communication option

1. Go to the Main menu.
2. Navigate to the Configuration menu, and then the Network menu.
3. Select the *BACnet Parameters* menu (BACNET).
4. Set the "BACnet Enable" parameter to "enable".
  - After a power up, if BACnet communication is enabled ("BACnet Enable" = ENABLE), chiller objects will be created.

Table Name: BACNET      PIC Table Type: 13H      Instance: depends on equipment      //MAINMENU/CONFIG/Network

	Point Name	Displayed text*	Status	Default	Unit
1	bacena	BACnet Enable	disable / enable	disable	-
2	bacunit	Metric unit	no / yes	yes	-
3	network	Network	1 to 40000	1600	-
4	udpport	UDP Port Number	47808 to 47823	47808	-
5	bac_id	Device Id manual	1 to 4194302	1600001	-
6	auid_opt	Device Id Auto Option	disable / enable	disable	-
7	balmena	Alarm reporting	disable / enable	enable	-
8	mng_occ	BACnet Manage Occupancy	no / yes	no	-
9	conifnam	IP port interface name	0 to 1	0	-
10		0 = J15			
11		1 = J16			

\*Displayed text may differ depending on the language selected. See also section 1.1 BACnet Parameters.



**Please note that changing parameters in the BACnet table will cause a software reboot.**



**Use a BACnet device discovery tool, e.g. BDT, to verify communication with BACnet devices – Chiller must be discovered.**



**Updating configuration, including Network IP address, mask address, gateway address parameters MUST be followed by a user power cycle – in order to makes these changes effective in BACnet stack.**

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	11 OF 46

### 3.2 BACnet Parameters (BACNET)

BACNET PARAMETERS (BACNET)	
<b>BACnet enable</b>	This parameter is used to enable BACnet communication.
<b>Metric unit</b>	<b>Metric units</b> and <b>Imperial units</b> are supported. By default, BACnet data will be displayed in metric units.
<b>Network</b>	The BACnet network value can be modified between 1 and 40000. By default, it is set to 1600.
<b>UDP Port</b>	The BACnet UDP port value can be modified between 47808 (BAC0) to 40823 (BACF). By default, it is set to 47808 (BAC0).
<b>Device Id manual</b>	By default, the manual deviceID set through the user interface is taken into account. The default value (1600001) is used to recognize the Chiller device on a BACnet network. The first two digits are the BACnet Vendor Id (16). The device ID MUST be unique over the BACnet bus. This parameter can be modified (from 1 to 4 194 302) if more than one Chiller is connected to the same BACnet network (or following the customer request). By default, the device Instance cannot be modified from BACnet Network.
<b>Device Id Auto Option</b>	This option is used to determine if the DeviceID is set from the user interface or from the BACnet network: <b>Disable (default setting):</b> Manual device ID from User Interface is taken into account. <b>Enable:</b> Device ID is set from the network. When Enabled, the current deviceID will be automatically set with the last deviceID value written from the BACnetNetwork.
<b>Alarm reporting</b>	This setting is used to determine if Alarm message can be sent to BMS or not. <b>Disable:</b> Alarm messages are not sent. <b>Enable (default setting):</b> Alarm messages are sent as Event notifications to BMS regarding properties of Notification class object.

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	12 OF 46

<p><b>BACnet Manage Occupancy</b></p>	<p>Chiller occupancy can be managed by either CCN or BACnet (they are totally independent). This "BACnet Manage Occupancy" parameter is used to select the Occupancy source (CCN or BACnet).</p> <p><b>Yes:</b> If BACnet is selected [BACnet_mng_occ = Yes], then BACnet Occupancy Control [BACnet_occ_ctrl] allows for determining if Occupancy source is managed by BACnet Schedule and Calendar objects or through BMS writings to BACnet_BMS_OCC object.</p> <p><i>Note about Schedule/calendar objects:</i> If "BACnet manage occupancy" is "YES", then if the calendar object PV value is False (today is not a holiday) then CHIL_OCC will be set by the schedule object output. If Today is a holiday (PV value = TRUE), then CHIL_OCC will be set to "NO".</p> <p>If BACnet manages occupancy then its output is written into GENUNIT_CHIL_OCC parameter.</p>
<p><b>IP port interface name</b></p>	<p>The 7-inch controller is equipped with 2 Ethernet ports.</p> <p>BACnet network is set to 1 ("eth1" / J16) by default, but for user convenience it may be changed to 0 ("eth0" / J15).</p> <p><i>Note: This is not applicable to 4.3-inch controller which is equipped with only one Ethernet port ("eth1"(J5)).</i></p>



**The Chiller Controller MUST BE in "Network" mode to be controlled from BACnet. Occupancy status from BACnet is ignored in "Local" mode.**

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	13 OF 46

### 3.3 Device ID setting

In the equipment, there are three mechanisms available to set the Device ID:

- 1) Manual (default): The deviceID is set through the local user interface.
- 2) Not Auto-Generated: The deviceID is set through BACnet Network.
- 3) Auto-Generated: The deviceID is determined by equipment calculation.

The “**Device Id Auto Option**” is available only on the local user interface.

- By default, it is set to “**Disable**”.
  - In this condition, the Manual Device ID set from the local User Interface is taken into account.
  - The ObjectIdentifier property of the deviceObject is read-only.
- If the “Device Id Auto Option” is set to “**Enable**”, then the device Instance can be set from the BACnet Network.

**Warning: The deviceID will be instantaneously modified, so the equipment won't be accessible to its previous deviceID.**

The additional proprietary property of the device object called "AUTO\_IDENTITY\_SCHEME" allows for determining the method to set deviceID (this property is also available on WebCtrl / i-Vu BMS through device driver “extras” page).

Its value could be:

- Not auto-generated (0 = default)
- Auto-generated: If the Value is “Auto Generated ...”, then proprietary mechanism is activated. The device ID will be equal to the value of “Auto Identify Base” property x 100 + CCN address.



**Writing Device ID Base or changing CCN address won't cause a device reboot. It is necessary to reboot the chiller controller to take into account the auto-generated device ID.**



**Device ID Base is written into Network Number and vice versa.**



**For DeviceID calculation: If CCN address is greater than “99”, then “1” will be used.**

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	14 OF 46

## 4 BACNET OBJECTS

### 4.1 BACnet chiller objects

Depending on the chiller type, the BACnet stack may contain up to 1000 BACnet objects, including the following types:

- ANALOG\_VALUE (**AV**)
- BINARY\_VALUE (**BV**)
- MULTISTATE VALUE (**MV**)
- One (1) device object
- One (1) Notification Class object for alarm reporting (**NC**)
- One (1) calendar object to manage holidays (**CAL**)
- One (1) schedule object to manage weekly schedule (**SCH**)
- One (1) event log object (**EL**)
- One (1) program object
- Up to 50 Trend Log objects (**TL**)
- Eight (8) file objects



**Objects' names are built from the concatenation of the menu name (table name) and the point name.**

*Example:*

Menu name (table name)	Point name	Object name
GENCONF	off_on_d	GENCONF_off_on_d
<i>General Configuration</i>	<i>Unit Off to On Delay</i>	<i>Unit Off to On Delay</i>

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	15 OF 46

## 4.2 Device object

The Device object type defines a standardized object whose properties represent the externally visible characteristics of a BACnet Device.

The Device object is referenced by its Object\_Identifier property which is unique to the BACnet device and it is also unique throughout the BACnet internetwork.



**See BACnet PICS (section 7) and refer to BACnet ASHRAE specification for properties description.**

### Additional Proprietary properties supported:

DST_OFFSET	3801	N/A Integer, in minutes and may be negative. Represents how much to change the time by.
ALLOW_LOCAL_SCHEDULE_EDIT	3803	Allows the user to determine whether the local display should allow the user to edit schedules or not.  BOOL datatype: 0 = FALSE (WebCtrl can only edit Schedule) 1 = TRUE (Local UI can only edit Schedule): <i>Not applicable to controller application</i>
EQUIPMENT_SERIAL_NUMBER	3820	N/A
RNET_ENABLE	3821	N/A
AUTO_IDENTITY_SCHEME	4149	ENUM datatype: 0 = Not Auto-Generated 1 = Auto-Generated and overrides device identifier
AUTO_IDENTITY_BASE	4150	UNS datatype: This value is used to calculate unique device identifier when it is auto-generated.  The algorithm is: device instance = auto-identity-base*100 + CCN address.  Example: device instance = 1600*100 + 11 = 160011.
CONTROLLER_SERIAL_NUMBER	4153	Returns Software P/N

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	16 OF 46

### 4.3 Analog value object

The Analog Value object type defines a standardized object whose properties represent the externally visible characteristics of an analog value.

#### Properties supported

Mandatory properties are supported by each object. Optional properties required to support COV, CMD, proprietary LOCK may or may not be present depending on the object. Analog Value objects are classified by type, where each type supports mandatory properties and a set of optional properties.



**See BACnet PICS (section 7), BACnet object list (section 9) and refer to BACnet ASHRAE specification for properties description.**



**See also COV (section 1.1), Commandable (section 0) and Lock option (section 4.16).**



**AV objects implementation does not support Intrinsic Reporting (IR) option.**



ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	17 OF 46

## 4.4 Binary value object

The Binary Value object type defines a standardized object whose properties represent the externally visible characteristics of a binary value.

The "binary value" may have only one of two distinct states referred to as ACTIVE and INACTIVE.

### Properties supported

Mandatory properties are supported by each object.

Optional properties required to support IR, CMD, proprietary LOCK may or may not be present depending on the object.

Binary Value objects are classified by type, where each type supports mandatory properties and a set of optional properties.



See BACnet PICS (section 7), BACnet object list (section 9) and refer to BACnet ASHRAE specification for properties description.



See also Intrinsic Reporting (section 0), Commandable (section 0) and Lock option (section 4.16).



BV objects implementation does not support Change of Value (COV) option.

## 4.5 Multistate value object

The Multi-state Value object type defines a standardized object whose properties represent the externally visible characteristics of a multi-state value.

The Present\_Value property is an unsigned integer representing the state.

The State\_Text property associates a description with each state.

### Properties supported

Mandatory properties are supported by each object. Optional properties required to support CMD, proprietary LOCK may or may not be present depending on the object.

Multistate Value objects are classified by type. Each type supports mandatory properties and a set of optional properties.



The CCN value corresponding to the MV object shall always be equal to the MV object present value MINUS 1.



See BACnet PICS (section 7), BACnet object list (section 9) and refer to BACnet ASHRAE specification for properties description.



See also Commandable (section 0) and Lock option (section 4.16).



MV objects implementation does not support Change of Value (COV) option.  
MV objects implementation does not support Intrinsic Reporting (IR) option.

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	18 OF 46

## 4.6 Notification class object

The Notification Class object is used to specify the handling and routing of events to one or more destinations. The Notification Class object defines the priorities to be used in event-notification messages, whether acknowledgment by an application process or human operator is required, and it also defines when during the week given destinations are to be used (at what time periods). For chiller application, there is only one notification class object. The object instance is 1.

### Important

The following two first priorities are common to all recipients, the third one is dedicated to each recipient:

- Priority
- User Ack required
- Recipient List

The priority is used for event notifications. Priorities shall range from 0 to 255 inclusive. A lower number indicates a higher priority. Default value is 0.

The Ack required property represent whether user acknowledgment shall be required in notifications generated.

3 transitions can require user acknowledgement:

- TOOFFNORMAL
- TO-FAULT
- TO-NORMAL

The notification class object can contain up to 2 recipients. These devices are listed in the recipient list property of the object.

For each recipient, there is a set of parameters to configure:

- Recipient Identification
- Valid days
- From time to time
- Process Identifier
- Issue Notification
- Transitions

The recipient can be identified by their IP address or by their Device name.

- By default, the recipient is available all the week day long at any time. This can be modified if the recipient is not available a week day and or at a certain period of the day.
- The recipient can ask for a confirmed or unconfirmed notification. The confirmed notification shall require a communication acknowledgement from the recipient.
- The process identifier is 1 (default). This is the handle of the process within the recipient device that is to receive the event notification.

3 transitions can issue notification messages:

- TOOFFNORMAL
- TO-FAULT
- TO-NORMAL



**See BACnet PICS (section 7) and refer to BACnet ASHRAE specification for properties description.**

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	19 OF 46

## 4.7 Event log object

The Event Log object records event notifications with timestamps and other pertinent data in an internal buffer for subsequent retrieval. Each timestamped buffer entry is called an event log "record".

For chiller application, there is only one event log object. The object instance is 1.

The Event Log object maintains an internal fixed-size buffer of 250 records. This buffer fills as event log records are added. If the buffer becomes full, the least recent records are overwritten when new records are added, or a collection may be set to stop.

- Logging may be enabled and disabled through the Enable property. Event Log enabling and disabling is recorded in the log buffer.
- When Enabled, logging may be started and stopped at dates and times specified by the Start\_Time and Stop\_Time properties.
- Logging starting or stopping is not recorded in the log buffer.



**See BACnet PICS (section 7) and refer to BACnet ASHRAE specification for properties description.**

## 4.8 Trend log object

The Trend Log object monitors a property of a referenced object and, when predefined conditions are met, saves ("logs") the value of the property and a timestamp in an internal buffer for subsequent retrieval. The data may be logged periodically, or upon a change of value. Each timestamped buffer entry is called a trend log "record".

For the equipment, the property of the referenced objects resides in the same device as the Trend Log object and the Trend Log Instance is the instance of the referenced object. Up to 50 Trend Log objects may reside in the device.

The referenced property value may be recorded upon COV subscription or periodic poll according to "Logging Type" property (Triggered type is not supported).

Each Trend Log object maintains an internal, optionally fixed-size buffer of 250 records.



**See BACnet PICS (section 7) and refer to BACnet ASHRAE specification for properties description.**

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	20 OF 46

## 4.9 Schedule object

The Schedule object type defines a standardized object used to describe a periodic schedule that may recur during a range of dates, with optional exceptions at arbitrary times on arbitrary dates. The Schedule object also serves as a binding between these scheduled times and the writing of specified "values" to Chiller Occupancy at those times.

Schedules are divided into days, where there are two types of days: normal days within a week and exception days.

The current state of the Schedule object is represented by the value of its Present\_Value property, which is calculated using the time/value pairs from the Weekly\_Schedule and Exception\_Schedule properties, with a default value for use when no schedules are in effect.

For the equipment, there is only one schedule object. The object instance is 1.

The status of the schedule & calendar objects is refreshed every minute (60 seconds).

### Proprietary properties

The following proprietary properties are supported:

EXCEPTION_SCHEDULE_DESCRIPTION	554
NEXT_TRANSITION_TIME	3813 date and time values for next schedule transition
MINUTES_REMAINING	3814 minutes remaining for next schedule transition



**See BACnet PICS (section 7) and refer to BACnet ASHRAE specification for properties description.**

### How to enable BACnet schedule for the equipment

To be effective, the controller must be in "Network" mode and the "BACnet Manage Occupancy" parameter available in BACnet Parameters menu (BACNET) has to be set to "YES". If this parameter is equal to "NO", then the CCN Chiller schedule will be taken into account.

If the occupancy from schedule is selected (BACnet\_BMS\_OCC =2), then the Present Value indicates the current value of the schedule.

The normal calculation of the value of the Present Value property is as follows:

- 1) Find the highest relative priority.  
Exception\_Schedule array element that is in effect for the current day and whose current value (see method below) is not NULL, and assign that value to the Present\_Value property.
- 2) If the Present\_Value was not assigned in the previous step, then evaluate the current value of the Weekly\_Schedule array element for the current day and if that value is not NULL, assign it to the Present\_Value property.
- 3) If the Present\_Value was not assigned in the previous steps, then assign the value of the Schedule\_Default property to the Present\_Value property. The method for evaluating the current value of a schedule (either exception or weekly) is to find the latest element in the list of BACnetTimeValues that occurs on or before the current time, and then use that element's value as the current value for the schedule. If no such an element is found, then the current value for the schedule shall be NULL.

These calculations are such that they can be performed at any time and the correct value of Present\_Value property will result.

Notice that the Present\_Value property will be assigned the value of the Schedule\_Default property at 00:00 of any given day, unless there is an entry for 00:00 in effect for that day. If a scheduled event logically begins on one day and ends on another, an entry at 00:00 shall be placed in the schedule that is in effect for the second day, and for any subsequent days of the event's duration, to ensure the correct result whenever Present\_Value is calculated.

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	21 OF 46

If the occupancy from BACnet BMS is selected (BACnet\_BMS\_OCC = 0 or 1), then regarding the request:

- BACnet\_BMS\_OCC = 1 => BMS request = Occ => CHIL\_OCC = YES
- BACnet\_BMS\_OCC = 0 => BMS request = Unocc => CHIL\_OCC = NO

**Up to 7 Weekly Schedules can be entered and saved.**

- A Weekly schedule has no priority attached.
- The Schedule object supports 20 Exception Schedules.

There are 7 possible exception types\*:

- Weekly (1)
- Date (1)
- Date Range (1)
- Date List (1 per date)
- Wild Card (1)
- Continuous (2)
- Dated weekly (1)

*\* As given in brackets, this exception type may use more than entry to be saved.*

The schedule proprietary property EXCEPTION\_SCHEDULE\_DESCRIPTION can be edited by iVu WebCTRL if the Device Object proprietary property ALLOW\_LOCAL\_SCHEDULE\_EDIT is set to FALSE.

If the Device Object proprietary property ALLOW\_LOCAL\_SCHEDULE\_EDIT is set to TRUE, then the schedule proprietary property EXCEPTION\_SCHEDULE\_DESCRIPTION cannot be accessed.

By default, the Device Object proprietary property ALLOW\_LOCAL\_SCHEDULE\_EDIT is set to FALSE.

ALLOW_LOCAL_SCHEDULE_EDIT	EXCEPTION_SCHEDULE_DESCRIPTION FROM WebCtrl
False	Accessible
True	Access denied

Up to 16 descriptions can be saved, but up to 20 exception schedules can be entered. The last 4 ones have no exception description saved.

It works like a FIFO: Last ExceptSched description entered is at position 01. Descriptions are saved.

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	22 OF 46

## 4.10 Calendar object

The Calendar object type defines a standardized object used to describe a list of calendar dates, which might be thought of as "holidays", "special events", or simply as a list of dates.

For chiller application, there is only one calendar object. The object instance is 1.



**See BACnet PICS (section 7) and refer to BACnet ASHRAE specification for properties description.**

There are 3 Member Types for calendar periods:

- Date
- Date Range
- BACnetWeekNday also named WildCard

### How to enable calendar

To be effective, the "BACnet Manage Occupancy" parameter available in BACnet Parameters menu (BACNET) has to be set to "YES".

The Present value indicates the current value of the calendar: TRUE if the current date is in the Date\_List and FALSE if it is not.

When calendar present value is true, then today is a holiday because it matches one of the dates in the calendar object. CHIL\_OCC is set to UNOCCUPIED.

When false, the calendar object does not contain today's date. CHIL\_OCC is set by the schedule object or by a BMS regarding BACnet\_BMS\_OCC value.

Up to 10 entries of the Calendar object can be saved.

## 4.11 File object

The File object type defines a standardized object that is used to describe properties of data files that may be accessed using File Services (atomic read and atomic write file).

File objects are mainly used for I-Vu, WebCtrl compatibility.



**See BACnet PICS (section 7) and refer to BACnet ASHRAE specification for properties description.**

## 4.12 Program object

The Program object type defines a standardized object whose properties represent the externally visible characteristics of an application program. The 'program\_location' property is where i-Vu or WebCTRL store the 'display-name' of the equipment. This property is shown in iVu/WebCTRL on the tree as the name of the equipment when we upload the device.

The user is allowed to change this value. WebCTRL will write the change to the device.

The 'program\_location' property is writable and non-volatile.



**See BACnet PICS (section 7) and refer to BACnet ASHRAE specification for properties description.**

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	23 OF 46

### 4.13 Change Of value (COV)

**Change of Value** is an event that occurs when a measured or calculated analogue value changes by a predefined amount.

Change of value (COV) reporting allows a COV-client to subscribe to a COV-server, on a permanent or temporary basis, to receive reports of some changes of value of some referenced property based on fixed criteria.

The COV option is set at BACnet stack construction. It cannot be added on field.

For object supporting COV, the COV increment property is required and added to the object.

**COV Increment** specifies the increment to be used in determining that a change of value has occurred.

#### Important

- If the variation of the Present Value exceeds (positive or negative) this increment, then a notification is sent to the subscriber.
- The COV increment is configurable through BACnet.
- The COV subscription can be set for a time duration (lifetime parameter > 0) or for an infinite duration.
- The PIC software will reject COV subscription service when Lifetime parameter is equal to zero with the error "Value out of Range".
- The list of the subscription can be found in the device object property "active\_cov\_subscription".
- The device will allow up to 6 COV subscribers for a given object. Additional subscriptions will be rejected with the "no-space-to-add-list-element" error.
- The entire list of active-COV-subscriptions can be retrieved by using the ReadRange service, 10 max at a time.



**The device shall allow up to 6 COV subscribers for a given object. Additional subscriptions shall be rejected with the “no-space-to-add-list-element” error.**

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	24 OF 46

## 4.14 Intrinsic reporting

Intrinsic reporting is the detection and reporting of an alarm or event, based on algorithm defined as part of the object type specification.

For the INTRINSIC REPORTING option (IR) the alarm configuration and the configuration of the equipment to be notified are required. Otherwise, the option will not be active.

Intrinsic reporting allows a BACnet device to provide one or more event sources, intrinsic to the device, that generate event notifications that may be directed to one or more destinations.

The Notification Class object is used to specify the handling and routing of events to one or more destinations.

**For objects supporting IR, the following required properties are added to the object.**

• Time_Delay	0 (default) – Read only
• Notification_Class	1 (default) – Read only
• Alarm_Value	0 default – Read only
• Event_Enable BACnet	{101} default – Read Write
• Acked_Transitions	{111} default – Read only
• Notify_Type	1 (default) – Read only
• Event_Time_Stamps	Read only

These properties are configurable through BACnet.

The IR option is set at BACnet stack construction. It cannot be added on field. The alarm configuration (see Event Enable Reporting parameter) and the configuration of the Notification Class object properties must be set properly.

Regarding Chiller application only BV object named ALM\*\*\* support Intrinsic reporting.

The equipment shall set the BV object present value and "in alarm" status flag according to its internal item value, as follows:

- item value = 0 : BV object present value = 0            "in alarm" = False
- item value = 1 : BV object present value = 1            "in alarm" = True

The equipment will resend *alarm notification* if *acknowledgement frame type* is not received for *Confirmed Event Notification* on or before the expiry of six seconds after *alarm notification*.

It will resend *alarm notification* three times.



ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	25 OF 46

## 4.15 Commandable

AV, BV, MV objects can support the commandable option. The **Commandable** option reflects the state of the output.

For those objects, the following required properties must be added:

- Priority\_Array
- Relinquish\_Default

The CMD option is set at BACnet stack construction. It cannot be added on field.

Objects with Commandable option are usually named with the "\_wr" suffix.

If the Local Operating Type is set to "Network", then it is possible to control the Unit from BACnet by writing these objects. The highest priority value of the commandable object will be copied to the present value of the object using the same name with the "\_rd" suffix.

*Example:*

*CTRL\_POINT\_wr highest priority value copied to CTRL\_POINT\_rd present value*

If the Local Operating Type is set to Local or Remote, then the Priority value won't be applied and the value determined by the controller will be used:

- The present value of the object name with the "\_rd" suffix (example: CTRL\_POINT\_rd) will still reflect the current software value.
- The BACnet priority level corresponds to the CCN override level (1:1). If this BACnet priority level is removed, the priority level that is immediately below will be applied to the corresponding CCN point (CCN "Auto" command will be applied first).
- When a CCN override level is applied from CCN, the CCN override level will be the BACnet priority level.

## 4.16 LOCK

The equipment supports a "LOCK" proprietary concept for "locked" and "locked values" on a point. This is a concept used to temporarily bypass a non-working sensor or to test logic behaviour under certain conditions. These two proprietary properties are supported by AV, BV and MV objects.

LOCK	3804	The LOCK property is an indication of whether (TRUE) or not (FALSE) the PRESENT_VALUE is overridden by the LOCKED_VALUE property. This property is writable.
LOCKED_VALUE	3805	This property has the same data type as the PRESENT_VALUE in this object. This value can be NULL. This property is writable.

When locking is enabled (LOCK = TRUE), the object present value will be updated with the LOCKED\_VALUE property.

When locking is disabled (LOCK = FALSE) for commandable objects, the object present value is restored and ALC\_LOCKED\_VALUE is no more used.

<b>ECG-UG-18-011</b>	<b>REVISION</b>	<b>DATE</b>	<b>PAGE</b>
BACnet option	A	August 2019	26 OF 46

## **4.17 Read Write Access to Chiller**

Writing AV, BV, MV "Present Value" is authorized by the BACnet protocol for all objects.

However, the Chiller application will authorize or won't authorize the "Present value" to be written in Chiller database regarding the "access" object parameter (Read Only (RO) or Read/Write (RW)).

"Access" parameter is not a BACnet property. This is a local and internal parameter used at BACnet stack construction.

If a "present value" property with an access parameter equal to Read only (RO) is written, then the present value will be overwritten by the chiller application with the previous value.

Objects with "present value" in Read Only access are all objects used for Chiller configuration and status.

Objects with "present value" in Read/Write access are objects used for setpoint configuration (named with a SETPOINT\_ prefix) and Commandable objects with a \_wr suffix.

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	27 OF 46

## 5 I-VU, WEBCTRL COMPATIBILITY

### 5.1 General overview

i-Vu/WebCtrl is designed to be a plug and play system. This means that once controllers have basic individual configuration completed, the i-Vu/WebCtrl server can scan and build up a system with minimal user effort.

Files necessary to build the system are automatically uploaded from the controller or retrieved from application library file(s).

To accomplish the plug and play goal, controllers shall have their equipment, graphics, and driver files defined and downloaded at factory level (they will be ready for discovery prior to iVu/WebCtrl being used).

### 5.2 Colour chart

The following colours are used for thermographic floor plans by WebCtrl/i-Vu. Colours represent the current state of the equipment's operation.

#### Colour Chart supported:

Colour	Status Code	Condition Indicated	Comment
Red	9	Cooling Alarm	Cooling Mode Chiller status is Tripout
Orange	8	Maximum cooling	Cooling Mode When GENUNIT_CAP_T = 100%
Yellow	7	Moderate cooling	Cooling Mode When GENUNIT_CAP_T > 0%
Light Blue	4	Moderate heating	Heating Mode When GENUNIT_CAP_T > 0%
Dark Blue	3	Maximum heating	Heating Mode When GENUNIT_CAP_T = 100%
Red	2	Heating alarm	Heating Mode Chiller status is Tripout

**Prime value:** Prime' represents the primary function of equipment the PIC is controlling.

"Prime" is one single most important value (number) for a controller.

For the equipment, the Prime value is the present value of the CAPACTRL\_ctrl\_wt object.

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	28 OF 46

### 5.3 Backup & Restore Config file

The device will allow a user at i-Vu/WebCtrl user interface or 3<sup>rd</sup> party BMS to backup or restore all its operating configuration parameters.

The files to be backed-up and restored shall be listed in a file (BACNET\_BACKUP.TXT) that must be present on the PIC file system.

#### The Backup procedure consists of the following steps:

1. The device receives a Reinitialize-Device Start-Backup command.
2. It reads and follows instructions listed in BACNET\_BACKUP.TXT file.
3. It fails the backup procedure if something is wrong (i.e. Required file missing).
4. It zips all copied files into BACNET\_BACKUP.ZIP
5. Indicates that the Backup procedure succeeded in the device object.
6. The BMS reads the backup and restores state property.
7. If it was successfully completed, then the BMS reads the FILE object instance 2 to upload BACNET\_BACKUP.ZIP via Atomic Read file.

#### The Restore procedure consists of the following steps:

1. The device receives a Reinitialize-Device Start-Restore command.
2. It sets the device object's Backup & Restore state property to "preparing for backup".
3. It sets the device object's System Status property to "backup in progress".
4. The device does nothing else. The BACnet client is supposed to write the configuration to be restored via Atomic Write file commands to the configuration file object, then it sends a Reinitialize-Device End-Restore command.
5. The device receives a Reinitialize-Device End-Restore command.
6. It reads and follows instructions listed in BACNET\_BACKUP.TXT
7. It fails the restore procedure if something is wrong (i.e. Required file missing).
8. Set the indicators to show that the Restore procedure has succeeded.
9. Send a "Reboot" command to the main device software module.
10. Wait for the reboot to occur.


ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	29 OF 46


## 6 IP ADDRESS SETTINGS

### 6.1 IP address controller

The IP address information can be accessed via the System menu available on the controller user interface.

#### To go to IP address settings

1. Go to the home screen on the controller user interface.
2. Press the **System** menu button  in the upper-right corner of the screen.
3. Select the *Network* menu (NETWORK).




### 6.2 IP address modification

If necessary, you may change unit IP address on the controller user interface or via the web browser (the web browser interface looks similar to the touch screen).

#### To modify unit IP address

1. Go to the *Network* menu (NETWORK).
  - The first page displays eth0 (J15) settings.
  - The second page displays eth1 (J16) settings.
2. Change IP address and mask as necessary.
3. Press the Save button to confirm or the Cancel button to cancel changes.



ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	30 OF 46

## 7 BACNET PICS

This section contains the Protocol Implementation Conformance Statement (PICS) and BACnet® Interoperability Building Blocks (BIBBs) for the BACnet stack as required by the American National Standards Institute/American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ANSI/ASHRAE) Standard 135-2010, BACnet protocol.

BACnet interoperability building blocks are collections of one or more BACnet services. This document includes a listing of the BIBBs currently supported by the device and BACnet stack.

The BACnet stack shall be native BACnet Advanced Application Controller (B-AAC).

### Date:

Vendor Name: Carrier  
Product Name: PIC6 - Chiller Series  
Product Model Number : PIC6  
Application Software Version:  
Firmware Revision:  
BACnet Protocol Revision: Version 1, Revision 12

### 7.1 Product Description

The chiller user-interface is a controller designed for UTC HVAC chillers. It communicates over BACnet/IP network.

### 7.2 BACnet Requirements BACnet Standardized Device Profile (Annex L)

- BACnet Operator Workstation (B-OWS)
- BACnet Advanced Operator Workstation (B-AWS)
- BACnet Operator Display (B-OD)
- BACnet Building Controller (B-BC)
- BACnet Advanced Application Controller (B-AAC)**
- BACnet Application Specific Controller (B-ASC)
- BACnet Smart Sensor (B-SS)
- BACnet Smart Actuator (B-SA)

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	31 OF 46

### 7.3 BACnet Interoperability Building Blocks (BIBBs)(Annex K)

Table below lists all the BIBBs that are required for the BACnet Advanced Application Controller (B-AAC) profile for the BACnet stack. The BIBBs that are not required for B-AAC Profile but supported in the BACnet stack are also listed.

Application Services (B-AAC)	Designation
<b>Required for B-AAC Profile</b>	
Data Sharing - Read Property – B	DS-RP-B
Data Sharing - Read Property Multiple – B	DS-RPM-B
Data Sharing - Write Property – B	DS-WP-B
Data Sharing - Write Property Multiple – B	DS-WPM-B
Alarm and Event-Notification Internal-B	AE-N-I-B
Alarm and Event-ACK-B	AE-ACK-B
Alarm and Event-Information-B	AE-INFO-B
Scheduling-Internal-B	SCHED-I-B
Device Management - Dynamic Device Binding – B	DM-DDB-B
Device Management- Dynamic Device Binding – A	DM-DDB-A
Device Management - Dynamic Object Binding – B	DM-DOB-B
Device Management - Device Communication Control – B	DM-DCC-B
Device Management - Time Synchronization – B	DM-TS-B
Device Management – UTC Time Synchronization – B	DB-UTC-B
Device Management - Reinitialize Device – B	DM-RD-B
<b>Not Required for B-AAC Profile but supported in the BACnet stack</b>	
<del>Device Management - Dynamic Object Binding – A</del>	<del>DM-DOB-A</del>
<del>Data Sharing - Read Property – A</del>	<del>DS-RP-A</del>
Device Management – Backup and Restore – B	DM-BR-B
Device Management – Private Transfer - B	DM-PT-B
<del>Device Management – Private Transfer - A</del>	<del>DM-PT-A</del>
Trending-Automated Trend Retrieval-B	T-ATR-B
Trending-Viewing and Modifying Trends Internal-B	T-VMT-I-B
<del>Data Sharing-COV-A</del>	<del>DS-COV-A</del>
Data Sharing-COV-B	DS-COV-B
Alarm and Event Management- Event Log – Internal - B	AE-EL-I-B

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	32 OF 46

## 7.4 Standard Object Types Supported

The following is a list of the standard object types as define by the standard. The objects checked are currently supported by this product. See the section in this document for the supported object type for details.

- Accumulator
- Analog Input
- Analog Output
- Analog Value
- Averaging
- Binary Input
- Binary Output
- Binary Value
- Calendar
- Command
- Device
- Event Log
- File
- Group
- Life Safety Point
- Life Safety Zone
- Loop
- Multistate Input
- Multistate Output
- Multistate Value
- Notification Class
- Program
- Pulse Converter
- Schedule
- Trend Log



**Dynamic Object creation and deletion are not supported.**



ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	33 OF 46

## 7.5 Device Object type

- Dynamically Creatable
- Dynamically Deletable

Property Name	Mandatory	Optional	Proprietary	RW	ID	Range
Object_Identifier	<input type="checkbox"/>			RW	75	
Object_Name	<input type="checkbox"/>			RW	77	
Object_Type	<input type="checkbox"/>			R	79	
System_Status	<input type="checkbox"/>			R	112	
Vendor_Name	<input type="checkbox"/>			R	121	
Vendor_Identifier	<input type="checkbox"/>			R	120	
Model_Name	<input type="checkbox"/>			R	70	
Firmware_Revision	<input type="checkbox"/>			R	44	
Application_Software_Version	<input type="checkbox"/>			R	12	
Location		<input type="checkbox"/>		RW	58	
Protocol_Version	<input type="checkbox"/>			R	98	
Protocol_Revision	<input type="checkbox"/>			R	139	
Protocol_Services_Supported	<input type="checkbox"/>			R	97	
Protocol_Object_Types_Supported	<input type="checkbox"/>			R	96	
Object_List	<input type="checkbox"/>			R	76	
Max_APDU_Length_Accepted	<input type="checkbox"/>			R	62	
Segmentation_Supported	<input type="checkbox"/>			R	107	
Local_Date		<input type="checkbox"/>		R	56	
Local_Time		<input type="checkbox"/>		R	57	
UTC_Offset		<input type="checkbox"/>		RW	119	
Daylight_Savings_Status		<input type="checkbox"/>		R	24	
APDU_Timeout	<input type="checkbox"/>			RW	10	
Number_Of_APDU_Retries	<input type="checkbox"/>			RW	73	
Device_Address_Binding	<input type="checkbox"/>			R	30	
Database_Revision	<input type="checkbox"/>			R	155	
Description		<input type="checkbox"/>		R	28	
Configuration Files		<input type="checkbox"/>		R	154	
Last Restore Time		<input type="checkbox"/>		R	157	
Backup Failure timeout		<input type="checkbox"/>		RW	153	
Backup and Restore State		<input type="checkbox"/>		R	338	
Backup preparation time		<input type="checkbox"/>		R	339	
Restore completion time		<input type="checkbox"/>		R	45	
Active_COV_Subscriptions		<input type="checkbox"/>		R	152	
DST_OFFSET			<input type="checkbox"/>	RW	3801	
ALLOW_LOCAL_SCHEDULE_EDIT			<input type="checkbox"/>	RW	3803	
EQUIPMENT_SERIAL_NUMBER			<input type="checkbox"/>	R	3820	
RNET_ENABLE			<input type="checkbox"/>	RW	3821	
AUTO_IDENTITY_SCHEME			<input type="checkbox"/>	RW	4149	
AUTO_IDENTITY_BASE			<input type="checkbox"/>	RW	4150	
CONTROLLER_SERIAL_NUMBER			<input type="checkbox"/>	R	4153	

<b>ECG-UG-18-011</b>	<b>REVISION</b>	<b>DATE</b>	<b>PAGE</b>
BACnet option	A	August 2019	34 OF 46

## 7.6 Analog value (AV) Object Type

- Dynamically Creatable
- Dynamically Deletable

Property Name	Mandatory	Optional	Proprietary	RW	ID	Type 1	Type 2	Type 3	Type 4	Type 5	Type 6
Object_Identifier	<input type="checkbox"/>			R	75	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Object_Name	<input type="checkbox"/>			R	77	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Object_Type	<input type="checkbox"/>			R	79	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Present_Value	<input type="checkbox"/>			RW	85	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Status_Flags	<input type="checkbox"/>			R	111	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Event_State	<input type="checkbox"/>			R	36	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Out_Of_Service	<input type="checkbox"/>			R	81	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Units	<input type="checkbox"/>			R	117	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Description		<input type="checkbox"/>		R	28	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Priority_Array		<input type="checkbox"/>		R	87	<input type="checkbox"/>	<input type="checkbox"/>				
Relinquish_Default		<input type="checkbox"/>		RW	104	<input type="checkbox"/>	<input type="checkbox"/>				
COV_Increment		<input type="checkbox"/>		RW	22	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>	
LOCK			<input type="checkbox"/>	RW	3804	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
LOCKED_VALUE			<input type="checkbox"/>	RW	3805	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		

For each Analog Value object in the list, type 1 to type 6 to define the presence of optional and proprietary properties.

<b>ECG-UG-18-011</b>	<b>REVISION</b>	<b>DATE</b>	<b>PAGE</b>
BACnet option	A	August 2019	35 OF 46

## 7.7 Binary Value (BV) Object Type

- Dynamically Creatable
- Dynamically Deletable

Property Name	Mandatory	Optional	Proprietary	RW	ID	Type 1	Type 2	Type 4	Type 5
Object_Identifier	<input type="checkbox"/>			R	75	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Object_Name	<input type="checkbox"/>			R	77	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Object_Type	<input type="checkbox"/>			R	79	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Present_Value	<input type="checkbox"/>			RW	85	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Status_Flags	<input type="checkbox"/>			R	111	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Event_State	<input type="checkbox"/>			R	36	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Out_Of_Service	<input type="checkbox"/>			R	81	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Description		<input type="checkbox"/>		R	28	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Inactive_Text		<input type="checkbox"/>			46	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Active_Text		<input type="checkbox"/>			4	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Priority_Array		<input type="checkbox"/>		R	87	<input type="checkbox"/>			
Relinquish_Default		<input type="checkbox"/>		RW	104	<input type="checkbox"/>			
Time_Delay		<input type="checkbox"/>		R	113				<input type="checkbox"/>
Notification_Class		<input type="checkbox"/>		R	17				<input type="checkbox"/>
Alarm_Value		<input type="checkbox"/>		R	6				<input type="checkbox"/>
Event_Enable BACnet		<input type="checkbox"/>		RW	35				<input type="checkbox"/>
Acked_Transitions		<input type="checkbox"/>		RW	0				<input type="checkbox"/>
Notify_Type		<input type="checkbox"/>		R	72				<input type="checkbox"/>
Event_Time_Stamps		<input type="checkbox"/>		R	130				<input type="checkbox"/>
ALC_LOCK			<input type="checkbox"/>	RW	3804	<input type="checkbox"/>	<input type="checkbox"/>		
ALC_LOCKED_VALUE			<input type="checkbox"/>	RW	3805	<input type="checkbox"/>	<input type="checkbox"/>		

For each Binary Value object in the list, type 1 to type 6 define the presence of optional and proprietary properties.

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	36 OF 46

## 7.8 Multi-state Value (MSV) Object Type

- Dynamically Creatable
- Dynamically Deletable

Property Name	Mandatory	Optional	Proprietary	RW	ID	Type 2	Type 4	Type 5
Object_Identifier	<input type="checkbox"/>			R	75	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Object_Name	<input type="checkbox"/>			R	77	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Object_Type	<input type="checkbox"/>			R	79	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Present_Value	<input type="checkbox"/>			RW	85	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Status_Flags	<input type="checkbox"/>			R	111	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Event_State	<input type="checkbox"/>			R	36	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Out_Of_Service	<input type="checkbox"/>			R	81	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Number_of_States	<input type="checkbox"/>			R	74	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Description		<input type="checkbox"/>		R	28	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
State_Text		<input type="checkbox"/>		R	110	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Priority_Array		<input type="checkbox"/>		R	87	<input type="checkbox"/>		
Relinquish_Default		<input type="checkbox"/>		RW	104	<input type="checkbox"/>		
ALC_LOCK			<input type="checkbox"/>	RW	3804	<input type="checkbox"/>	<input type="checkbox"/>	
ALC_LOCKED_VALUE			<input type="checkbox"/>	RW	3805	<input type="checkbox"/>	<input type="checkbox"/>	

For each Multi State Value object in the list, type 1 to type 6 define the presence of optional and proprietary properties.

## 7.9 Program Object Type

- Dynamically Creatable
- Dynamically Deletable

Property Name	Mandatory	Optional	Proprietary	RW	ID	Range
Object_Identifier	<input type="checkbox"/>			R	75	
Object_Name	<input type="checkbox"/>			R	77	
Object_Type	<input type="checkbox"/>			R	79	
Program_State	<input type="checkbox"/>			R	92	
Program_Change	<input type="checkbox"/>			RW	90	
Status_Flags	<input type="checkbox"/>			R	111	
Out_Of_Service	<input type="checkbox"/>			R	81	
Program Location		<input type="checkbox"/>		RW	91	

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	37 OF 46

## 7.10 Calendar Object Type

- Dynamically Creatable
- Dynamically Deletable

Property Name	Mandatory	Optional	Proprietary	RW	ID	Range
Object_Identifier	<input type="checkbox"/>			R	75	
Object_Name	<input type="checkbox"/>			R	77	
Object_Type	<input type="checkbox"/>			R	79	
Present_Value	<input type="checkbox"/>			R	85	
Date_List	<input type="checkbox"/>			RW	23	
Description		<input type="checkbox"/>		R	28	

## 7.11 File Object Type

- Dynamically Creatable
- Dynamically Deletable

Property Name	Mandatory	Optional	Proprietary	RW	ID	Range
Object_Identifier	<input type="checkbox"/>			R	75	
Object_Name	<input type="checkbox"/>			RW	77	
Object_Type	<input type="checkbox"/>			R	79	
File_Type	<input type="checkbox"/>			R	43	
File_Size	<input type="checkbox"/>			RW	42	
Modification_Date	<input type="checkbox"/>			RW	71	
Archive	<input type="checkbox"/>			RW	13	
Read_Only	<input type="checkbox"/>			R	99	
File_Access_Method	<input type="checkbox"/>			R	41	
Description		<input type="checkbox"/>		R	28	

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	38 OF 46

## 7.12 Schedule Object Type

- Dynamically Creatable
- Dynamically Deletable

Property Name	Mandatory	Optional	Proprietary	RW	ID	Range
Object_Identifier	<input type="checkbox"/>			R	75	
Object_Name	<input type="checkbox"/>			R	77	
Object_Type	<input type="checkbox"/>			R	79	
Present_Value	<input type="checkbox"/>			R	92	
Effective_Period	<input type="checkbox"/>			R	32	
Weekly_Schedule		<input type="checkbox"/>		RW	123	
Exception_Schedule		<input type="checkbox"/>		RW	38	
Schedule_Default	<input type="checkbox"/>			R	174	
List_Of_Object_Property_References	<input type="checkbox"/>			R	54	
Priority_For_Writing	<input type="checkbox"/>			R	88	
Status_Flags	<input type="checkbox"/>			R	111	
Reliability	<input type="checkbox"/>			R	103	
Out_Of_Service	<input type="checkbox"/>			R	81	
Exception-schedule-description			<input type="checkbox"/>	RW	557	
Next-transition-time			<input type="checkbox"/>	R	3813	
Minutes-remaining			<input type="checkbox"/>	R	3814	

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	39 OF 46

### 7.13 Trend Log (TL) Object Type

- Dynamically Creatable
- Dynamically Deletable

Property Name	Mandatory	Optional	Proprietary	RW	ID	Range
Object_Identifier	<input type="checkbox"/>			R	75	
Object_Name	<input type="checkbox"/>			R	77	
Object_Type	<input type="checkbox"/>			R	79	
Status_Flags	<input type="checkbox"/>			R	111	
Event_State	<input type="checkbox"/>			R	36	
Enable	<input type="checkbox"/>			RW	133	
Start-time		<input type="checkbox"/>		RW	142	
Stop-time		<input type="checkbox"/>		RW	143	
Stop-when-full	<input type="checkbox"/>			RW	144	
Log_device_object_property	<input type="checkbox"/>			R	132	
Log interval	<input type="checkbox"/>			RW	134	
Client COV Increment		<input type="checkbox"/>		RW	127	
Buffer-size	<input type="checkbox"/>			R	126	
Log-Buffer	<input type="checkbox"/>			R	131	
Record Count	<input type="checkbox"/>			RW	141	
Total record count	<input type="checkbox"/>			R	145	
Notification class		<input type="checkbox"/>		RW	17	
Records since-notification		<input type="checkbox"/>		R	140	
Last-notify-record		<input type="checkbox"/>		R	173	
Notification-threshold		<input type="checkbox"/>		RW	137	
Event-enable		<input type="checkbox"/>		RW	35	
Acked-transitions		<input type="checkbox"/>		RW	0	
Notify-type		<input type="checkbox"/>		R	72	
Event-time-stamps		<input type="checkbox"/>		R	130	
Logging Type	<input type="checkbox"/>			R	197	
Description		<input type="checkbox"/>		R	28	

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	40 OF 46

## 7.14 Notification Class (NC) Object Type

- Dynamically Creatable
- Dynamically Deletable

Property Name	Mandatory	Optional	Proprietary	RW	ID	Range
Object_Identifier	<input type="checkbox"/>			R	75	
Object_Name	<input type="checkbox"/>			R	77	
Object_Type	<input type="checkbox"/>			R	79	
Notification class	<input type="checkbox"/>			R	17	
Priority	<input type="checkbox"/>			RW	86	
Ack Required	<input type="checkbox"/>			RW	1	
Recipient List	<input type="checkbox"/>			RW	102	
Description		<input type="checkbox"/>		R	28	

## 7.15 Event Log (EL) Object Type

- Dynamically Creatable
- Dynamically Deletable

Property Name	Mandatory	Optional	Proprietary	RW	ID	Range
Object_Identifier	<input type="checkbox"/>			R	75	
Object_Name	<input type="checkbox"/>			R	77	
Object_Type	<input type="checkbox"/>			R	79	
Status_Flags	<input type="checkbox"/>			R	111	
Event_State	<input type="checkbox"/>			R	36	
Enable	<input type="checkbox"/>			RW	133	
Start-time		<input type="checkbox"/>		RW	142	
Stop-time		<input type="checkbox"/>		RW	143	
Stop-when-full	<input type="checkbox"/>			RW	144	
Buffer-size	<input type="checkbox"/>			R	126	
Log-Buffer	<input type="checkbox"/>			R	131	
Record Count	<input type="checkbox"/>			RW	141	
Total record count	<input type="checkbox"/>			R	145	
Notification class		<input type="checkbox"/>		RW	17	
Records since-notification		<input type="checkbox"/>		R	140	
Last-notify-record		<input type="checkbox"/>		R	173	
Notification-threshold		<input type="checkbox"/>		RW	137	
Event-enable		<input type="checkbox"/>		RW	35	
Acked-transitions		<input type="checkbox"/>		RW	0	
Notify-type		<input type="checkbox"/>		R	72	
Event-time-stamps		<input type="checkbox"/>		R	130	
Event-message-texts		<input type="checkbox"/>		R	351	
Description		<input type="checkbox"/>		R	28	



ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	41 OF 46

## 7.16 Data Link Layer Option

- BACnet IP (Annex J)**
- BACnet IP (Annex J), Foreign Device
- ISO 8802-3, Ethernet (Clause 7)
- ANSI/ATA 878.1, 2.5 MB ARCNET (Clause 8)
- ANSI/ATA 878.1, RS-485 ARCNET (Clause 8), baud rates:
- Master-Slave/Token-Passing (MS/TP) master (Clause 9), baud rates: 9600, 19200, 38400, 57600, 76800, 115200
- MS/TP slave (Clause 9), baud rates: 9600, 19200, 38400, 76800
- Point-To-Point, EIA 232 (Clause 10), baud rates:
- Point-To-Point, modem (Clause 10), baud rates:
- LonTalk, (Clause 11), medium:
- BACnet/ZigBee (ANNEX O)
- Other:

## 7.17 Segmentation Capability

- Segmented requests supported
- Segmented responses supported

## 7.18 Device Address Binding

*Is static device binding supported?* (Required for two-way communication between MS/TP slaves and other devices)

YES  NO

## 7.19 Networking Options

- Router, Clause 6 - List all routing configurations, e.g., ARCNET-Ethernet, Ethernet-MS/TP, etc.
- Annex H, BACnet Tunneling Router over IP
- BACnet/IP Broadcast Management Device (BBMD)

Does the BBMD support registrations by Foreign Devices?  YES  NO

Does the BBMD support network address translation?  YES  NO

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	42 OF 46

## 7.20 Network Security Options

- Non-secure Device - is capable of operating without BACnet Network Security.**
- Secure Device - is capable of using BACnet Network Security (NS-SD BIBB)
  - Multiple Application-Specific Keys
  - Supports encryption (NS-ED BIBB)
  - Key Server (NS-KS BIBB)

## 7.21 Character Sets Supported

Indicating support for multiple character sets does not imply that they can all be supported simultaneously.

- IBM®/Microsoft® Double-Byte Character Set (DBCS)
- ISO 8859-1
- ISO 10646 Universal Character Set-2 (UCS-2)
- ISO 10646 UCS Transformation Format (UTF-8)**
- ISO 10646 (UCS-4)
- Japanese Industrial Standard (JIS) X 0208

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	43 OF 46

## 7.22 SystemVu Supported Services

Table below lists all the BACnet standard application services.

The checked services are supported by the SystemVu.

Application Service	Initiates Requests	Executes Requests
ConfirmedEventNotification Service	<input type="checkbox"/>	
UnconfirmedEventNotification Service	<input type="checkbox"/>	
GetEventInformation Service		<input type="checkbox"/>
ReadProperty Service		<input type="checkbox"/>
ReadPropertyMultiple Service		<input type="checkbox"/>
WriteProperty Service		<input type="checkbox"/>
WritePropertyMultiple Service		<input type="checkbox"/>
DeviceCommunicationControl Service		<input type="checkbox"/>
ReinitializeDevice Service		<input type="checkbox"/>
Timesynchronization Service		<input type="checkbox"/>
UTCTimesynchronization Service		<input type="checkbox"/>
Who-Is		<input type="checkbox"/>
Who-Has		<input type="checkbox"/>
I-Am		<input type="checkbox"/>
I-Have		<input type="checkbox"/>
SubscribeCOV		<input type="checkbox"/>
ConfirmedCOVNotification		
UnConfirmedCOVNotification		
AcknowledgeAlarm		<input type="checkbox"/>
ReadRange		<input type="checkbox"/>
AtomicReadFile		<input type="checkbox"/>
AtomicWritefile		<input type="checkbox"/>
ConfirmedPrivateTransfer		<input type="checkbox"/>
UnconfirmedPrivateTransfer		<input type="checkbox"/>

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	44 OF 46

## 8 BACNET IP COMMUNICATION TROUBLESHOOTING

### 8.1 Communication troubleshooting

In the case of BACnet IP communication problem, i.e. the unit is not responding to the *Building Manager System*, please read the following to learn more about possible causes.

Possible cause	Solution
1. The BACnet activation is not detected by the chiller application	<ul style="list-style-type: none"> <li>In the Configuration menu, go to Network menu and open "BACnet Parameters" menu and check that "BACnet Enable" parameter is set to "enable".</li> <li>In the Main menu, open "Software Options" table, "OPT149: BACnet" parameter must be set to "YES".</li> </ul>
2. The Ethernet cable is not correctly connected	<ul style="list-style-type: none"> <li>On the Ethernet connector, verify that the green LED is ON and the orange LED is blinking (see also IOM Control).</li> <li>In Configuration menu, go to Network menu and open "BACnet Parameters" menu and check if the "BACnet network IF name" parameter matches Ethernet cable connection.</li> </ul>
3. Network parameters are invalid	<ul style="list-style-type: none"> <li>Go to the System menu on the user interface and verify all network parameters (see also section 6).</li> <li>Open a command prompt under Windows (Start &gt; Run &gt; type "cmd" &gt; OK). Type the command "ping" followed by the IP address of the device Ethernet port, (e.g. for eth0 by default <b>ping 169.254.1.1</b>). The equipment must respond.</li> </ul>
4. There is an IP router between the equipment and the BMS	<ul style="list-style-type: none"> <li>To verify the connection, you need to have any BDT software (BACnet Discovery Tool) installed. This software will allow you to display the list of devices connected to the BACnet network, including the physical names and instance numbers.</li> </ul>

To discover devices connected to the BACnet network:

1. Run the BDT software and execute the "Who Is" command.
2. A list of devices connected to the BACnet network will be displayed.
3. Find the required device according to the BACnet device instance configured, i.e. 1600001.

```

D:\dev\Bacnet\bdtd.exe
BACnet Discovery Tool v1.1
Contemporary Controls Copyright (C) 2008
portions copyright (C) 2005 Steve Karg
Broadcast: FFFFFFFFC0BA
Address: C9611EACC0BA
Sending Global Who-Is
Received I-Am Response from 169998 (vendor 24)
Received I-Am Response from 1623071 (vendor 16)
Received I-Am Response from 1623070 (vendor 16)
Received I-Am Response from 1623069 (vendor 16)
Received I-Am Response from 1623068 (vendor 16)
Received I-Am Response from 1623067 (vendor 16)
Received I-Am Response from 1623066 (vendor 16)
Received I-Am Response from 1623065 (vendor 16)
Received I-Am Response from 1600001 (vendor 16)
Received I-Am Response from 1623064 (vendor 16)
Received I-Am Response from 1623063 (vendor 16)
Received I-Am Response from 1623059 (vendor 16)
Received I-Am Response from 1623058 (vendor 16)

```

Free download is available at:  
[www.ccontrols.com/sd/bdt.htm](http://www.ccontrols.com/sd/bdt.htm)

<b>ECG-UG-18-011</b>	<b>REVISION</b>	<b>DATE</b>	<b>PAGE</b>
BACnet option	A	August 2019	45 OF 46

## **8.2 BACnet tool incompatibilities**

### **CAUSE:**

- If more than one BACnet client has to be installed on the same PC, an error message may be raised at BACnet tool start-up.

### **SOLUTION:**

- In the configuration panel, set the windows service called "BACstack protocol" to "manual" start-up type and start/stop it as necessary.

## **8.3 BDT cannot discover BACnet device(s)**

### **CAUSE:**

- Incorrect parameters configuration.
- IP router separates Chiller BACnet/IP network and PC BACnet/IP network.

### **SOLUTION:**

- Make sure network prefix and subnet number parameters are the same between the chiller controller (user interface) and the PC. Is Gateway IP address correct ?
- Install BBMD (BACnet Broadcast Management Device) devices on each BACnet/IP network.

ECG-UG-18-011	REVISION	DATE	PAGE
BACnet option	A	August 2019	46 OF 46

## 9 BACNET OBJECT LIST

### 9.1 Object name/instance

Objects name are built from CCN table name and CCN point name put together. Object descriptions are in English (the same as the ones in CCN tables).

Depending on chillers, the object instance can follow this logic:

Instances	Values	Comment
Pre-defined	1 to 899	AV, BV, MV mixed unique instance pre-defined
	900 to 959	Setpoints
	960 to 979	AV Starts, Hour
	980 to 999	Chiller Alarm 1...5
	1000 to 1899	AV, BV, MV Circuit A
	1960 to 1979	AV Starts, Hour Circuit A
	2000 to 2899	AV, BV Circuit B
	2960 to 2979	AV Starts, hour Circuit B
	3000 to 3899	AV, BV Circuit C
	3960 to 3979	AV Starts, hour Circuit C
Free	5000 to 9999	AV, BV, MV mixed without pre-defined instance
Built	10000 to 19999	CMD object named "_wr" Inst. = 10000 + Object Inst "_rd"
Built	1 to 9999	Trend Log, Inst. = Obj Ref inst.
Built	100000 to 999999	BV + Intrinsic Reporting option (Alarm) Inst = 100 000 + Alarm code
<ul style="list-style-type: none"> <li>Instance from 1 to 4999 will be pre-defined and common to all chillers (highlighted in blue in the table given above).</li> <li>Instance from 5000 to 9999 will be free for all chillers (highlighted in green in the table given above).</li> </ul>		

### 9.2 BACnet object list description

The object list description is available on demand in an EDE format type.

EDE file are xml file readable with Microsoft Excel and compatible with standard BACnet tools as BMS.

- BACnet objects are in Read Only access by default.
- BACnet objects starting with "SETPOINT\_" and "BACnet\_BMS\_OCC" object are in read/write access.
- BACnet objects ending with "\_wr" are commandable objects. Note that the chiller must be in "Network" mode to activate the linked chiller functionalities.
- "xxxx\_EMSTOP\_wr" is the chiller "Emergency Stop". "xxxx" represents the table name. This functionality is always activated.